

BAR CODE	DATE	BUILDING	LOCATION	TYPE	SIZE	PASS/FAIL	
6100	10/23/2018	COURT TOWER	FLOOR 1	SMOKE	11R	PASS	PNEUMATIC AIR BALANCE
6101	10/23/2018	COURT TOWER	FLOOR 1	SMOKE	11R	PASS	PNEUMATIC AIR BALANCE
6102	10/23/2018	COURT TOWER	FLOOR 1	SMOKE	16R	PASS	PNEUMATIC AIR BALANCE
6103	10/23/2018	COURT TOWER	FLOOR 1	SMOKE	48X12	PASS	PNEUMATIC AIR BALANCE
6104	10/23/2018	COURT TOWER	FLOOR 1	SMOKE	14R	PASS	PNEUMATIC AIR BALANCE
6105	10/15/2018	COURT TOWER	FLOOR 1	SMOKE	10R	PASS	PNEUMATIC AIR BALANCE
6106	10/15/2018	COURT TOWER	FLOOR 1	SMOKE	10R	PASS	PNEUMATIC AIR BALANCE
6107	10/15/2018	COURT TOWER	FLOOR 1	SMOKE	10R	PASS	PNEUMATIC AIR BALANCE
6108	10/15/2018	COURT TOWER	FLOOR 1	SMOKE	10X6	PASS	PNEUMATIC AIR BALANCE
6109	10/15/2018	COURT TOWER	FLOOR 1	SMOKE	10R	PASS	PNEUMATIC AIR BALANCE
6110	10/15/2018	COURT TOWER	FLOOR 1	SMOKE	10R	PASS	PNEUMATIC AIR BALANCE
6111	10/15/2018	COURT TOWER	FLOOR 1	SMOKE	48X12	PASS	PNEUMATIC AIR BALANCE
6112	10/17/2018	COURT TOWER	FLOOR 1	FIRE	48/12	PASS	STATIC B AIR BALANCE
6113	10/17/2018	COURT TOWER	FLOOR 1	SMOKE	16R	PASS	PNEUMATIC AIR BALANCE
6114	XXXXXXX	XXXXXXXXXX					
6115	10/15/2018	COURT TOWER	FLOOR 1	SMOKE	16R	PASS	PNEUMATIC AIR BALANCE
6116	10/17/2018	COURT TOWER	FLOOR 2	FIRE	16R	PASS	STATIC B AIR BALANCE
6117	10/17/2018	COURT TOWER	FLOOR 2	FIRE	48X12	PASS	STATIC B AIR BALANCE
6118	10/15/2018	COURT TOWER	FLOOR 1	SMOKE	48X12	PASS	PNEUMATIC AIR BALANCE
6119	10/17/2018	COURT TOWER	FLOOR 2	FIRE	16R	PASS	STATIC B AIR BALANCE
6120	10/15/2018	COURT TOWER	FLOOR 1	SMOKE	16R	PASS	PNEUMATIC AIR BALANCE
6121	10/16/2018	COURT TOWER	FLOOR2	FIRE	14R	PASS	STATIC B AIR BALANCE
6122	10/15/2018	COURT TOWER	FLOOR 1	SMOKE	16R	PASS	PNEUMATIC AIR BALANCE
6123	10/17/2018	COURT TOWER	FLOOR 2	FIRE	10R	PASS	STATIC B AIR BALANCE
6124	10/16/2018	COURT TOWER	FLOOR 2	FIRE	11R	PASS	STATIC B AIR BALANCE
6125	10/16/2018	COURT TOWER	FLOOR 2	FIRE	60X12 A/B	PASS	DYNAMIC AIR BALANCE
6126	10/16/2018	COURT TOWER	FLOOR 2	FIRE	18R	PASS	DYNAMIC AIR BALANCE
6127	10/16/2018	COURT TOWER	FLOOR 2	FIRE	14R	PASS	DYNAMIC AIR BALANCE
6128	10/15/2018	COURT TOWER	FLOOR 2	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6129	10/17/2018	COURT TOWER	FLOOR 2	FIRE	8R	PASS	DYNAMIC AIR BALANCE
6130	10/17/2018	COURT TOWER	FLOOR 2	SMOKE	8	PASS	PNEUMATIC AIR BALANCE
6131	10/17/2018	COURT TOWER	FLOOR 2	FIRE	6R	PASS	STATIC B AIR BALANCE
6132	10/17/2018	COURT TOWER	FLOOR 2	SMOKE	6R	PASS	PNEUMATIC AIR BALANCE
6133	10/16/2018	COURT TOWER	FLOOR 2	FIRE	10R	PASS	STATIC B AIR BALANCE
6134	10/22/2018	COURT TOWER	FLOOR 2	SMOKE	10R	PASS	PNEUMATIC AIR BALANCE
6135	10/16/2018	COURT TOWER	FLOOR 2	FIRE	12R	PASS	STATIC B AIR BALANCE
6136	10/16/2018	COURT TOWER	FLOOR 2	SMOKE	12R	PASS	PNEUMATIC AIR BALANCE

6137	10/22/2018	COURT TOWER	FLOOR 2	SMOKE	16R	PASS	PNEUMATIC AIR BALANCE
6138	10/29/2018	COURT TOWER	FLOOR 2	FIRE	16R	PASS	STATIC B AIR BALANCE
6139	10/29/2018	COURT TOWER	FLOOR 2	FIRE	48X12	PASS	STATIC B AIR BALANCE
6140	10/22/2018	COURT TOWER	FLOOR 2	SMOKE	48X12	PASS	PNEUMATIC AIR BALANCE
6141	10/29/2018	COURT TOWER	FLOOR 2	FIRE	13R	PASS	STATIC B AIR BALANCE
6142	10/22/2018	COURT TOWER	FLOOR 2	SMOKE	13R	PASS	PNEUMATIC AIR BALANCE
6143	10/29/2018	COURT TOWER	FLOOR 2	FIRE	8R	PASS	STATIC B AIR BALANCE
6144	10/29/2018	COURT TOWER	FLOOR 2	FIRE	8R	PASS	STATIC B AIR BALANCE
6145	10/29/2018	COURT TOWER	FLOOR 2	FIRE	8R	PASS	STATIC B AIR BALANCE
6146	10/29/2018	COURT TOWER	FLOOR 2	FIRE	8R	PASS	STATIC B AIR BALANCE
6147	10/22/2018	COURT TOWER	FLOOR 2	FIRE	10R	PASS	STATIC B AIR BALANCE
6148	XXXXXXX						
6149	XXXXXXX						
6150	10/22/2018	COURT TOWER	FLOOR 3	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6151	10/25/2018	COURT TOWER	FLOOR 3	FIRE	8R	PASS	STATIC B AIR BALANCE
6152	10/22/2018	COURT TOWER	FLOOR 3	SMOKE	16R	PASS	PNEUMATIC AIR BALANCE
6153	10/25/2018	COURT TOWER	FLOOR 3	FIRE	16R	PASS	STATIC B AIR BALANCE
6154	10/22/2018	COURT TOWER	FLOOR 3	SMOKE	48X12	PASS	PNEUMATIC AIR BALANCE
6155	10/25/2018	COURT TOWER	FLOOR 3	FIRE	48X12	PASS	STATIC B AIR BALANCE
6156	10/22/2018	COURT TOWER	FLOOR 3	SMOKE	12R	PASS	PNEUMATIC AIR BALANCE
6157	10/25/2018	COURT TOWER	FLOOR 3	FIRE	12R	PASS	STATIC B AIR BALANCE
6158	10/22/2018	COURT TOWER	FLOOR 3	SMOKE	14R	PASS	PNEUMATIC AIR BALANCE
6159	10/25/2018	COURT TOWER	FLOOR 3	FIRE	14R	PASS	STATIC B AIR BALANCE
6160	10/22/2018	COURT TOWER	FLOOR 3	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6161	10/25/2018	COURT TOWER	FLOOR 3	FIRE	8R	PASS	STATIC B AIR BALANCE
6162	10/22/2018	COURT TOWER	FLOOR 3	SMOKE	14R	PASS	PNEUMATIC AIR BALANCE
6163	10/25/2018	COURT TOWER	FLOOR 3	FIRE	14R	PASS	STATIC B AIR BALANCE
6164	10/23/2018	COURT TOWER	FLOOR 4	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6165	10/23/2018	COURT TOWER	FLOOR 4	FIRE	8R	PASS	STATIC B AIR BALANCE
6166	10/23/2018	COURT TOWER	FLOOR 4	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6167	10/23/2018	COURT TOWER	FLOOR 4	FIRE	8R	PASS	STATIC B AIR BALANCE
6168	10/23/2018	COURT TOWER	4TH FLOOR	FIRE	9R	PASS	STATIC B AIR BALANCE
6169	10/23/2018	COURT TOWER	4TH FLOOR	SMOKE	9R	PASS	PNEUMATIC AIR BALANCE
6170	10/23/2018	COURT TOWER	4TH FLOOR	FIRE	60X15	PASS	STATIC B AIR BALANCE
6171	10/23/2018	COURT TOWER	4TH FLOOR	SMOKE	60X15	PASS	PNEUMATIC AIR BALANCE
6172	10/23/2018	COURT TOWER	4TH FLOOR	FIRE	10R	PASS	STATIC B AIR BALANCE
6173	10/23/2018	COURT TOWER	4TH FLOOR	SMOKE	10R	PASS	PNEUMATIC AIR BALANCE
6174	10/23/2018	COURT TOWER	4TH FLOOR	FIRE	18X6	PASS	STATIC B AIR BALANCE
6175							

6176								
6177								
6178								
6179	10/23/2018	COURT TOWER	2ND FLOOR	FIRE	11R	PASS		STATIC B AIR BALANCE
6180	10/23/2018	COURT TOWER	2ND FLOOR	SMOKE	11R	PASS		PNEUMATIC AIR BALANCE
6181	10/23/2018	COURT TOWER	3RD FLOOR	FIRE	8R	PASS		STATIC B AIR BALANCE
6182	10/23/2018	COURT TOWER	3RD FLOOR	SMOKE	8R	PASS		PNEUMATIC AIR BALANCE
6183								
6184								
6185								
6186								
6187								
6188								
6189								
6190								
6191								
6192	10/25/2018	COURT TOWER	3RD FLOOR	FIRE	8R	PASS		RUSKIN STATIC
6193	10/25/2018	COURT TOWER	3RD FLOOR	FIRE	6R	PASS		RUSKIN STATIC
6194	10/25/2018	COURT TOWER	3RD FLOOR	FIRE	18X12	PASS		RUSKIN STATIC
6195	10/25/2018	COURT TOWER	3RD FLOOR	FIRE		PASS		RUSKIN STATIC
6196	10/25/2018	COURT TOWER	3RD FLOOR	FIRE	12R	PASS		RUSKIN STATIC
6197	10/25/2018	COURT TOWER	3RD FLOOR	FIRE		PASS		RUSKIN STATIC
6198	10/25/2018	COURT TOWER	3RD FLOOR	FIRE	8R	PASS		RUSKIN STATIC
6199	10/25/2018	COURT TOWER	3RD FLOOR	FIRE	12X10	PASS		RUSKIN STATIC
6200	10/25/2018	COURT TOWER	3RD FLOOR	FIRE	12X10	PASS		RUSKIN STATIC
6201	10/25/2018	COURT TOWER	3RD FLOOR	FIRE	48X12	PASS		RUSKIN STATIC
6202	10/26/2018	COURT TOWER	3RD FLOOR	FIRE	26X12	PASS		RUSKIN STATIC
6203	10/26/2018	COURT TOWER	3RD FLOOR	FIRE	26X12	PASS		RUSKIN STATIC
6204	10/26/2018	COURT TOWER	3RD FLOOR	FIRE	28X12	PASS		RUSKIN STATIC
6205	10/26/2018	COURT TOWER	3RD FLOOR	FIRE	30X18	PASS		RUSKIN STATIC
6206	10/26/2018	COURT TOWER	3RD FLOOR	FIRE	10R	PASS		RUSKIN STATIC
6207	10/26/2018	COURT TOWER	3RD FLOOR	FIRE	8R	PASS		RUSKIN STATIC
6208	10/26/2018	COURT TOWER	3RD FLOOR	FIRE		PASS		RUSKIN STATIC
6209	10/26/2018	COURT TOWER	3RD FLOOR	FIRE	10R	PASS		RUSKIN STATIC
6210	10/26/2018	COURT TOWER	3RD FLOOR	FIRE	10X12	PASS		RUSKIN STATIC
6211	10/29/2018	COURT TOWER	FLOOR 6	SMOKE	8R	FAIL		AIR BALANCE PNEUMATIC/END SWITCH/6211/6214/6216/SAME J BOX
6212	10/29/2018	COURT TOWER	FLOOR 6	FIRE	8R	PASS		STATIC B AIR BALANCE
6213	10/29/2018	COURT TOWER	FLOOR 6	FIRE	8R	PASS		STATIC B AIR BALANCE
6214	10/29/2018	COURT TOWER	FLOOR 6	SMOKE	8R	FAIL		AIR BALANCE PNEUMATIC/END SWITCH/6211/6214/6216/SAME J BOX

6215	10/29/2018	COURT TOWER	FLOOR 6	FIRE	12X8	PASS	STATIC B AIR BALANCE
6216	10/29/2018	COURT TOWER	FLOOR 6	SMOKE	2R	FAIL	AIR BALANCE PNEUMATIC/END SWITCH/6211/6214/6216/SAME J BOX
6217	10/29/2018	COURT TOWER	FLOOR 6	FIRE	60X12	PASS	STATIC B AIR BALANCE
6218	10/29/2018	COURT TOWER	FLOOR 6	SMOKE	60X12	PASS	AIR BALANCE PNEUMATIC
6219	10/29/2018	COURT TOWER	FLOOR 6	SMOKE	16R	PASS	AIR BALANCE PNEUMATIC
6220	10/29/2018	COURT TOWER	FLOOR 6	SMOKE	60X12	PASS	AIR BALANCE PNEUMATIC
6221	10/29/2018	COURT TOWER	FLOOR 6	FIRE	60X12	PASS	STATIC B AIR BALANCE
6222	10/30/2018	COURT TOWER	FLOOR 6	SMOKE	16R	FAIL	FIRE WALL ISSUES/AIR BALANCE PNEUMATIC/END SWITCH/
6223	10/30/2018	COURT TOWER	FLOOR 6	FIRE	8R	PASS	STATIC B AIR BALANCE
6224	10/30/2018	COURT TOWER	FLOOR 6	SMOKE	8R	FAIL	AIR BALANCE PNEUMATIC/SAME ZONE AS 6211/6214
6225	10/30/2018	COURT TOWER	FLOOR 6	FIRE	10R	PASS	STATIC B AIR BALANCE
6226	10/30/2018	COURT TOWER	FLOOR 6	FIRE	10R	PASS	STATIC B AIR BALANCE
6227	10/30/2018	COURT TOWER	FLOOR 6	FIRE			STATIC B AIR BALANCE
6228	10/30/2018	COURT TOWER	FLOOR 6	SMOKE	12R	FAIL	NO AIR IN LINE TO PNEUMATIC ACTUATOR
6229	10/30/2018	COURT TOWER	FLOOR 6	FIRE	20X10	PASS	STATIC B AIR BALANCE
6230	10/30/2018	COURT TOWER	FLOOR 6	SMOKE	8R	FAIL	AIR BALANCE PNEUMATIC/SAME ZONE AS 6211/6214
6231	10/30/2018	COURT TOWER	FLOOR 6	FIRE	8R	PASS	STATIC B AIR BALANCE
6232	10/30/2018	COURT TOWER	FLOOR 6	SMOKE	8R	FAIL	AIR BALANCE PNEUMATIC/SAME ZONE AS 6211/6214
6233	10/30/2018	COURT TOWER	FLOOR 6	FIRE	8R	PASS	STATIC B AIR BALANCE
6234	10/30/2018	COURT TOWER	FLOOR 6	SMOKE	16R	PASS	AIR BALANCE PNEUMATIC
6235	10/30/2018	COURT TOWER	FLOOR 6	FIRE	16R	PASS	STATIC B AIR BALANCE
6236	10/30/2018	COURT TOWER	FLOOR 6	SMOKE	8R	FAIL	END SWITCH/AIR BALANCE PNEUMATIC
6237	10/30/2018	COURT TOWER	FLOOR 6	FIRE	8R	PASS	STATIC B AIR BALANCE
6238	10/30/2018	COURT TOWER	FLOOR 6	SMOKE	12R	PASS	AIR BALANCE PNEUMATIC
6239	10/31/2018	COURT TOWER	FLOOR 7	FIRE	18/12	PASS	STATIC B AIR BALANCE
6240	10/31/2018	COURT TOWER	FLOOR 7	SMOKE	18/12	PASS	AIR BALANCE PNEUMATIC
6241	10/31/2018	COURT TOWER	FLOOR 7	FIRE	8R	PASS	STATIC B AIR BALANCE
6242	10/31/2018	COURT TOWER	FLOOR 7	SMOKE	8R	PASS	AIR BALANCE PNEUMATIC
6243	10/31/2018	COURT TOWER	FLOOR 7	FIRE	8R	PASS	STATIC B AIR BALANCE
6244	10/31/2018	COURT TOWER	FLOOR 7	SMOKE	8R	PASS	AIR BALANCE PNEUMATIC
6245	10/31/2018	COURT TOWER	FLOOR 7	FIRE	12R	PASS	STATIC B AIR BALANCE
6246	10/31/2018	COURT TOWER	FLOOR 7	SMOKE	12R	PASS	AIR BALANCE PNEUMATIC
6247	10/31/2018	COURT TOWER	FLOOR 7	FIRE	8R	PASS	STATIC B AIR BALANCE
6248	10/31/2018	COURT TOWER	FLOOR 7	SMOKE	8R	PASS	AIR BALANCE PNEUMATIC
6249	10/31/2018	COURT TOWER	FLOOR 7	FIRE	60/12	PASS	STATIC B AIR BALANCE
6250	10/31/2018	COURT TOWER	FLOOR 7	SMOKE	60/12	PASS	AIR BALANCE PNEUMATIC
6251	10/31/2018	COURT TOWER	FLOOR 7	FIRE	14/6	PASS	STATIC B AIR BALANCE
6252	10/31/2018	COURT TOWER	FLOOR 7	SMOKE	8R	PASS	AIR BALANCE PNEUMATIC
6253	10/31/2018	COURT TOWER	FLOOR 7	FIRE	8R	PASS	STATIC B AIR BALANCE

6254	10/31/2018	COURT TOWER	FLOOR 7	SMOKE	8R	PASS	AIR BALANCE PNEUMATIC
6255	10/31/2018	COURT TOWER	FLOOR 7	FIRE	6-Oct	PASS	STATIC B AIR BALANCE
6256	11/1/2018	COURT TOWER	FLOOR 7	FIRE	14/8	PASS	STATIC B AIR BALANCE
6257	11/1/2018	COURT TOWER	FLOOR 7	FIRE	8R	PASS	STATIC B AIR BALANCE
6258	11/1/2018	COURT TOWER	FLOOR 7	SMOKE	8R	PASS	AIR BALANCE PNEUMATIC
6259	11/1/2018	COURT TOWER	FLOOR 7	SMOKE	7R	PASS	PNEUMATIC AIR BALANCE
6260	11/1/2018	COURT TOWER	FLOOR 7	FIRE	7R	PASS	STATIC B AIR BALANCE
6261	11/1/2018	COURT TOWER	FLOOR 7	SMOKE	9R	PASS	PNEUMATIC AIR BALANCE
6262	11/1/2018	COURT TOWER	FLOOR 7	FIRE	9R	PASS	STATIC B AIR BALANCE
6263	11/1/2018	COURT TOWER	FLOOR 7	SMOKE	13R	PASS	PNEUMATIC AIR BALANCE
6264	11/1/2018	COURT TOWER	FLOOR 7	FIRE	13R	PASS	STATIC B AIR BALANCE
6265	11/1/2018	COURT TOWER	FLOOR 7	FIRE	16/8	PASS	STATIC B AIR BALANCE
6266	11/1/2018	COURT TOWER	FLOOR 8	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6267	11/1/2018	COURT TOWER	FLOOR 7	FIRE	10R	PASS	STATIC B AIR BALANCE
6268	11/2/2018	COURT TOWER	FLOOR 8	FIRE	20X12	PASS	STATIC B AIR BALANCE
6269	11/2/2018	COURT TOWER	FLOOR 7	FIRE	12R	PASS	STATIC B AIR BALANCE
6270	11/2/2018	COURT TOWER	FLOOR 7	SMOKE	12R	PASS	PNEUMATIC AIR BALANCE
6271	11/2/2018	COURT TOWER	FLOOR 7	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6272	11/2/2018	COURT TOWER	FLOOR 7	FIRE	8R	PASS	STATIC B AIR BALANCE
6273	11/2/2018	COURT TOWER	FLOOR 7	FIRE	8R	PASS	STATIC B AIR BALANCE
6274	11/2/2018	COURT TOWER	FLOOR 7	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6275	XXXXXXX		XXXXX		XXXXX		
6276	11/2/2018	COURT TOWER	FLOOR 7	SMOKE	14R	PASS	PNEUMATIC AIR BALANCE
6277	11/2/2018	COURT TOWER	FLOOR 7	SMOKE	11R	PASS	PNEUMATIC AIR BALANCE
6278	11/2/2018	COURT TOWER	FLOOR 7	FIRE	11R	PASS	STATIC B AIR BALANCE
6279	11/2/2018	COURT TOWER	8TH FLOOR	FIRE	18X10	PASS	STATIC B AIR BALANCE
6280	11/2/2018	COURT TOWER	8TH FLOOR	FIRE	48X14	PASS	STATIC B AIR BALANCE
6281	11/2/2018	COURT TOWER	8TH FLOOR	SMOKE	48X10	PASS	PNEUMATIC AIR BALANCE
6282	XXXXXXX		XXXXX				
6283	11/19/2018	COURT TOWER	7TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6284	11/19/2018	COURT TOWER	7TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6285	11/19/2018	COURT TOWER	7TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6286	11/19/2018	COURT TOWER	7TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6287	11/19/2018	COURT TOWER	7TH FLOOR	FIRE	11R	PASS	STATIC B AIR BALANCE
6288	11/19/2018	COURT TOWER	7TH FLOOR	SMOKE	11R	PASS	PNEUMATIC AIR BALANCE
6289	11/5/2018	COURT TOWER	8TH FLOOR	FIRE	18X12	PASS	STATIC B AIR BALANCE
6290	11/5/2018	COURT TOWER	8TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6291	11/5/2018	COURT TOWER	8TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6292	11/5/2018	COURT TOWER	8TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE

6293	11/5/2018	COURT TOWER	8TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6294	11/5/2018	COURT TOWER	8TH FLOOR	SMOKE	18X12	FAIL	DOES NOT ACTIVATE BY ANY TRIGGER
6295	11/5/2018	COURT TOWER	8TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6296	11/5/2018	COURT TOWER	8TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6297	11/5/2018	COURT TOWER	8TH FLOOR	FIRE	10R	PASS	STATIC B AIR BALANCE
6298	11/5/2018	COURT TOWER	8TH FLOOR	SMOKE	10R	PASS	PNEUMATIC AIR BALANCE
6299	11/6/2018	COURT TOWER	4TH FLOOR	FIRE	12R	PASS	STATIC B AIR BALANCE
6300	11/6/2018	COURT TOWER	4TH FLOOR	SMOKE	12R	PASS	PNEUMATIC AIR BALANCE
6301	11/6/2018	COURT TOWER	4TH FLOOR	FIRE	11R	PASS	STATIC B AIR BALANCE
6302	11/6/2018	COURT TOWER	4TH FLOOR	SMOKE	11R	PASS	PNEUMATIC AIR BALANCE
6303							
6304	11/6/2018	COURT TOWER	9TH FLOOR	SMOKE	10R	PASS	PNEUMATIC AIR BALANCE
6305	11/6/2018	COURT TOWER	9TH FLOOR	FIRE	10R	PASS	STATIC B AIR BALANCE
6306	11/7/2018	COURT TOWER	9TH FLOOR	SMOKE	13R	PASS	PNEUMATIC AIR BALANCE
6307	11/7/2018	COURT TOWER	9TH FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6308	11/7/2018	COURT TOWER	9TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6309	11/7/2018	COURT TOWER	9TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6310	11/7/2018	COURT TOWER	9TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6311	11/7/2018	COURT TOWER	9TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6312	11/7/2018	COURT TOWER	9TH FLOOR	SMOKE	15R	PASS	PNEUMATIC AIR BALANCE
6313	11/7/2018	COURT TOWER	9TH FLOOR	FIRE	16X10	PASS	STATIC B AIR BALANCE
6314	11/7/2018	COURT TOWER	9TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6315	11/7/2018	COURT TOWER	9TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6316	11/7/2018	COURT TOWER	9TH FLOOR	SMOKE	11R	PASS	PNEUMATIC AIR BALANCE
6317	11/7/2018	COURT TOWER	9TH FLOOR	FIRE	11R	PASS	STATIC B AIR BALANCE
6318	11/7/2018	COURT TOWER	9TH FLOOR	SMOKE	9R	PASS	PNEUMATIC AIR BALANCE
6319	11/7/2018	COURT TOWER	9TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6320	11/7/2018	COURT TOWER	9TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6321	11/8/208	COURT TOWER	9TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6322	11/8/208	COURT TOWER	9TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6323	11/8/208	COURT TOWER	9TH FLOOR	SMOKE	14R	PASS	PNEUMATIC AIR BALANCE
6324	11/8/208	COURT TOWER	9TH FLOOR	SMOKE	14R	PASS	PNEUMATIC AIR BALANCE
6325	11/8/208	COURT TOWER	9TH FLOOR	FIRE	14R	PASS	STATIC B AIR BALANCE
6326	11/8/208	COURT TOWER	9TH FLOOR	FIRE	16X10	PASS	STATIC B AIR BALANCE
6327	11/14/2018	COURT TOWER	8TH FLOOR	FIRE	6R	PASS	STATIC B AIR BALANCE
6328	11/14/2018	COURT TOWER	8TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6329	11/14/2018	COURT TOWER	8TH FLOOR	FIRE	16X8	PASS	STATIC B AIR BALANCE
6330	11/14/2018	COURT TOWER	8TH FLOOR	FIRE	11R	PASS	STATIC B AIR BALANCE
6331	11/14/2018	COURT TOWER	8TH FLOOR	FIRE	14X6	PASS	STATIC B AIR BALANCE

6332	11/14/2018	COURT TOWER	8TH FLOOR	FIRE	15R	PASS	STATIC B AIR BALANCE
6333	11/14/2018	COURT TOWER	8TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6334	11/14/2018	COURT TOWER	8TH FLOOR	SMOKE	13R	PASS	PNEUMATIC AIR BALANCE
6335	11/15/2018	COURT TOWER	8TH FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6336	11/15/2018	COURT TOWER	8TH FLOOR	SMOKE	14R	PASS	PNEUMATIC AIR BALANCE
6337	11/15/2018	COURT TOWER	8TH FLOOR	FIRE	60X12	PASS	STATIC B AIR BALANCE
6338	11/15/2018	COURT TOWER	8TH FLOOR	SMOKE	60X12	PASS	PNEUMATIC AIR BALANCE
6339	11/15/2018	COURT TOWER	8TH FLOOR	SMOKE	12R	PASS	PNEUMATIC AIR BALANCE
6340	11/15/2018	COURT TOWER	9TH FLOOR	SMOKE	60X12	PASS	PNEUMATIC AIR BALANCE
6341	11/15/2018	COURT TOWER	9TH FLOOR	FIRE	60X12	PASS	STATIC B AIR BALANCE
6342	11/15/2018	COURT TOWER	9TH FLOOR	SMOKE	60X12	PASS	PNEUMATIC AIR BALANCE
6343	11/15/2018	COURT TOWER	9TH FLOOR	FIRE	60X12	PASS	STATIC B AIR BALANCE
6344	11/15/2018	COURT TOWER	9TH FLOOR	SMOKE	6R	PASS	PNEUMATIC AIR BALANCE
6345	11/15/2018	COURT TOWER	9TH FLOOR	FIRE	6R	PASS	STATIC B AIR BALANCE
6346	11/16/2018	COURT TOWER	10TH FLOOR	FIRE	16X12	PASS	STATIC B AIR BALANCE
6347	11/16/2018	COURT TOWER	10TH FLOOR	SMOKE	14R	PASS	PNEUMATIC AIR BALANCE
6348	11/16/2018	COURT TOWER	10TH FLOOR	FIRE	14R	PASS	STATIC B AIR BALANCE
6349	XXXXXXX	XXXXXXXXXX	XXXXX	XXXX	XXXX	XXXX	
6350	11/16/2018	COURT TOWER	10TH FLOOR	SMOKE	16R	PASS	PNEUMATIC AIR BALANCE
6351	11/16/2018	COURT TOWER	10TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6352	11/16/2018	COURT TOWER	10TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6353	11/16/2018	COURT TOWER	10TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6354	11/16/2018	COURT TOWER	10TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6355	11/16/2018	COURT TOWER	10TH FLOOR	FIRE	10R	PASS	STATIC B AIR BALANCE
6356	11/16/2018	COURT TOWER	10TH FLOOR	SMOKE	10R	PASS	PNEUMATIC AIR BALANCE
6357	11/16/2018	COURT TOWER	10TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6358	11/16/2018	COURT TOWER	10TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6359	11/16/2018	COURT TOWER	10TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6360	11/16/2018	COURT TOWER	10TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6361	11/16/2018	COURT TOWER	10TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6362	11/16/2018	COURT TOWER	10TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6363	11/16/2018	COURT TOWER	10TH FLOOR	FIRE	16X10	PASS	STATIC B AIR BALANCE
6364	11/16/2018	COURT TOWER	10TH FLOOR	SMOKE	16X10	XXXX	NO LONGER PART OF SMOKE SYSTEM PER JCI
6365	11/16/2018	COURT TOWER	10TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6366	11/19/2018	COURT TOWER	10TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6367	11/19/2018	COURT TOWER	10TH FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6368	11/19/2018	COURT TOWER	10TH FLOOR	SMOKE	13R	PASS	PNEUMATIC AIR BALANCE
6369	11/19/2018	COURT TOWER	10TH FLOOR	FIRE	48X12	PASS	STATIC B AIR BALANCE
6370	11/19/2018	COURT TOWER	10TH FLOOR	SMOKE	48X12	PASS	PNEUMATIC AIR BALANCE

6371	11/19/2018	COURT TOWER	10TH FLOOR	FIRE	48X12	PASS	STATIC B AIR BALANCE
6372	11/19/2018	COURT TOWER	10TH FLOOR	SMOKE	48X12	PASS	PNEUMATIC AIR BALANCE
6373	11/19/2018	COURT TOWER	10TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6374	11/19/2018	COURT TOWER	10TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6375	11/19/2018	COURT TOWER	10TH FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6376	11/19/2018	COURT TOWER	10TH FLOOR	SMOKE	13R	PASS	PNEUMATIC AIR BALANCE
6377	11/19/2018	COURT TOWER	10TH FLOOR	FIRE	12X10	PASS	STATIC B AIR BALANCE
6378	11/19/2018	COURT TOWER	10TH FLOOR	SMOKE	12X10	PASS	PNEUMATIC AIR BALANCE
6379	11/19/2018	COURT TOWER	10TH FLOOR	SMOKE	16X8	XXXX	NO LONGER PART OF SMOKE SYSTEM PER JCI
6380	11/20/2018	COURT TOWER	11TH FLOOR	FIRE	24X10	PASS	STATIC B AIR BALANCE
6381	11/20/2018	COURT TOWER	11TH FLOOR	SMOKE	24X10	PASS	PNEUMATIC AIR BALANCE
6382	11/20/2018	COURT TOWER	11TH FLOOR	SMOKE	10R	PASS	PNEUMATIC AIR BALANCE
6383	11/20/2018	COURT TOWER	11TH FLOOR	FIRE	10R	PASS	STATIC B AIR BALANCE
6384	11/20/2018	COURT TOWER	11TH FLOOR	SMOKE	6R	PASS	PNEUMATIC AIR BALANCE
6385	11/20/2018	COURT TOWER	11TH FLOOR	FIRE	6R	PASS	STATIC B AIR BALANCE
6386	11/20/2018	COURT TOWER	11TH FLOOR	SMOKE	48X12	PASS	PNEUMATIC AIR BALANCE
6387	11/20/2018	COURT TOWER	11TH FLOOR	FIRE	48X12	PASS	STATIC B AIR BALANCE
6388	11/20/2018	COURT TOWER	11TH FLOOR	SMOKE	48X12	PASS	PNEUMATIC AIR BALANCE
6389	11/20/2018	COURT TOWER	11TH FLOOR	FIRE	48X12	PASS	STATIC B AIR BALANCE
6390	11/20/2018	COURT TOWER	11TH FLOOR	SMOKE	6R	PASS	PNEUMATIC AIR BALANCE
6391	11/21/2018	COURT TOWER	11TH FLOOR	FIRE	6R	PASS	STATIC B AIR BALANCE
6392	11/21/2018	COURT TOWER	11TH FLOOR	SMOKE	9R	PASS	PNEUMATIC AIR BALANCE
6393	11/21/2018	COURT TOWER	11TH FLOOR	FIRE	9R	PASS	STATIC B AIR BALANCE
6394	11/21/2018	COURT TOWER	11TH FLOOR	SMOKE	10R	PASS	PNEUMATIC AIR BALANCE
6395	11/21/2018	COURT TOWER	11TH FLOOR	FIRE	10R	PASS	STATIC B AIR BALANCE
6396	11/21/2018	COURT TOWER	11TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6397	11/21/2018	COURT TOWER	11TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6398	11/21/2018	COURT TOWER	11TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6399	11/21/2018	COURT TOWER	11TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6400	11/21/2018	COURT TOWER	11TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6401	11/21/2018	COURT TOWER	11TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6402	11/21/2018	COURT TOWER	11TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6403	11/21/2018	COURT TOWER	11TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6404	11/26/2018	COURT TOWER	11TH FLOOR	SMOKE	10R	PASS	PNEUMATIC AIR BALANCE
6405	11/26/2018	COURT TOWER	11TH FLOOR	FIRE	10R	PASS	STATIC B AIR BALANCE
6406	11/26/2018	COURT TOWER	11TH FLOOR	SMOKE	13R	PASS	PNEUMATIC AIR BALANCE
6407	11/26/2018	COURT TOWER	11TH FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6408	11/26/2018	COURT TOWER	11TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6409	11/26/2018	COURT TOWER	11TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE



6410	11/26/2018	COURT TOWER	11TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6411	11/26/2018	COURT TOWER	11TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6412	11/26/2018	COURT TOWER	11TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6413	11/26/2018	COURT TOWER	11TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6414	11/26/2018	COURT TOWER	11TH FLOOR	SMOKE	13R	PASS	PNEUMATIC AIR BALANCE
6415	11/26/2018	COURT TOWER	11TH FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6416	11/27/2018	COURT TOWER	6TH FLOOR	FIRE	30R	PASS	SHAFT DAMPERS DYNAMIC RUSKIN
6417	11/27/2018	COURT TOWER	6TH FLOOR	FIRE	26X24	PASS	SHAFT DAMPERS DYNAMIC AIR BALANCE
6418	11/27/2018	COURT TOWER	6TH FLOOR	FIRE	30R	PASS	SHAFT DAMPERS DYNAMIC AIR BALANCE
6419	11/27/2018	COURT TOWER	6TH FLOOR	FIRE	36X34	PASS	SHAFT DAMPERS DYNAMIC AIR BALANCE
6420	11/27/2018	COURT TOWER	6TH FLOOR	FIRE	30R	PASS	SHAFT DAMPERS DYNAMIC AIR BALANCE
6421	11/27/2018	COURT TOWER	6TH FLOOR	FIRE	30R	PASS	SHAFT DAMPERS DYNAMIC RUSKIN
6422	11/27/2018	COURT TOWER	6TH FLOOR	FIRE	66X66	PASS	SHAFT DAMPERS DYNAMIC AIR BALANCE
6423	11/27/2018	COURT TOWER	6TH FLOOR	FIRE	66X66	PASS	SHAFT DAMPERS DYNAMIC AIR BALANCE
6424	11/27/2018	COURT TOWER	6TH FLOOR	FIRE	66X66	PASS	SHAFT DAMPERS DYNAMIC AIR BALANCE
6425	11/27/2018	COURT TOWER	6TH FLOOR	FIRE	24X24	PASS	SHAFT DAMPERS DYNAMIC AIR BALANCE
6426	11/27/2018	COURT TOWER	6TH FLOOR	FIRE	24R	PASS	SHAFT DAMPERS DYNAMIC RUSKIN
6427	11/27/2018	COURT TOWER	6TH FLOOR	FIRE	21R	PASS	SHAFT DAMPERS DYNAMIC AIR BALANCE
6428	11/27/2018	COURT TOWER	6TH FLOOR	FIRE	24R	PASS	SHAFT DAMPERS DYNAMIC AIR BALANCE
6429	11/27/2018	COURT TOWER	6TH FLOOR	FIRE	26X28	PASS	SHAFT DAMPERS DYNAMIC AIR BALANCE
6430	11/28/2018	COURT TOWER	12TH FLOOR	SMOKE	6R	PASS	PNEUMATIC AIR BALANCE
6431	11/28/2018	COURT TOWER	12TH FLOOR	FIRE	6R	PASS	STATIC B AIR BALANCE
6432	11/28/2018	COURT TOWER	12TH FLOOR	SMOKE	60X12	PASS	PNEUMATIC AIR BALANCE
6433	11/28/2018	COURT TOWER	12TH FLOOR	FIRE	60X12	PASS	STATIC B AIR BALANCE
6434	11/28/2018	COURT TOWER	12TH FLOOR	SMOKE	60X12	PASS	PNEUMATIC AIR BALANCE
6435	11/28/2018	COURT TOWER	12TH FLOOR	FIRE	6	PASS	STATIC B AIR BALANCE
6436	11/28/2018	COURT TOWER	12TH FLOOR	SMOKE	13	PASS	PNEUMATIC AIR BALANCE
6437	11/28/2018	COURT TOWER	12TH FLOOR	FIRE	60X12	PASS	STATIC B AIR BALANCE
6438	11/28/2018	COURT TOWER	12TH FLOOR	SMOKE	13R	PASS	PNEUMATIC AIR BALANCE
6439	11/28/2018	COURT TOWER	12TH FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6440	11/28/2018	COURT TOWER	12TH FLOOR	SMOKE	13R	PASS	PNEUMATIC AIR BALANCE
6441	11/28/2018	COURT TOWER	12TH FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6442	11/28/2018	COURT TOWER	12TH FLOOR	SMOKE	13R	PASS	PNEUMATIC AIR BALANCE
6443	11/28/2018	COURT TOWER	12TH FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6444	11/28/2018	COURT TOWER	12TH FLOOR	SMOKE	12R	XXXX	NO LONGER PART OF FIRE SYSTEM PER JCI
6445	11/28/2018	COURT TOWER	12TH FLOOR	FIRE	12R	XXXX	NO LONGER PART OF FIRE SYSTEM PER JCI
6446	11/29/2018	COURT TOWER	12TH FLOOR	SMOKE	13R	PASS	PNEUMATIC AIR BALANCE
6447	11/29/2018	COURT TOWER	12TH FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6448	11/29/2018	COURT TOWER	12TH FLOOR	FIRE	12X8	PASS	STATIC B AIR BALANCE

6449	11/29/2018	COURT TOWER	12TH FLOOR	FIRE	6R	PASS	STATIC B AIR BALANCE
6450	11/29/2018	COURT TOWER	12TH FLOOR	SMOKE	6R	PASS	PNEUMATIC AIR BALANCE
6451	11/29/2018	COURT TOWER	12TH FLOOR	FIRE	5R	PASS	STATIC B AIR BALANCE
6452	11/29/2018	COURT TOWER	12TH FLOOR	SMOKE	5R	PASS	PNEUMATIC AIR BALANCE
6453	11/29/2018	COURT TOWER	12TH FLOOR	FIRE	12R	PASS	STATIC B AIR BALANCE
6454	11/29/2018	COURT TOWER	12TH FLOOR	SMOKE	12R	PASS	PNEUMATIC AIR BALANCE
6455	11/29/2018	COURT TOWER	12TH FLOOR	FIRE	12X8	PASS	STATIC B AIR BALANCE
6456	11/29/2018	COURT TOWER	12TH FLOOR	SMOKE	12R	PASS	PNEUMATIC AIR BALANCE
6457	11/29/2018	COURT TOWER	12TH FLOOR	FIRE	12R	PASS	STATIC B AIR BALANCE
6458	11/29/2018	COURT TOWER	12TH FLOOR	SMOKE	10X8	PASS	PNEUMATIC AIR BALANCE
6459	11/29/2018	COURT TOWER	12TH FLOOR	FIRE	10X8	PASS	STATIC B AIR BALANCE
6460	11/29/2018	COURT TOWER	12TH FLOOR	SMOKE	12X8	PASS	PNEUMATIC AIR BALANCE
6461	11/30/2018	COURT TOWER	12TH FLOOR	FIRE	12X8	PASS	STATIC B AIR BALANCE
6462	11/30/2018	COURT TOWER	12TH FLOOR	SMOKE	18R	PASS	PNEUMATIC AIR BALANCE
6463	11/30/2018	COURT TOWER	12TH FLOOR	FIRE	11R	PASS	STATIC B AIR BALANCE
6464	11/30/2018	COURT TOWER	12TH FLOOR	SMOKE	11R	PASS	PNEUMATIC AIR BALANCE
6465	11/30/2018	COURT TOWER	12TH FLOOR	FIRE	6R	PASS	STATIC B AIR BALANCE
6466	11/30/2018	COURT TOWER	12TH FLOOR	SMOKE	6R	PASS	PNEUMATIC AIR BALANCE
6467	11/30/2018	COURT TOWER	12TH FLOOR	FIRE	24X24	PASS	STATIC B AIR BALANCE
6468	11/30/2018	COURT TOWER	12TH FLOOR	SMOKE	18X14	PASS	PNEUMATIC AIR BALANCE
6469	11/30/2018	COURT TOWER	12TH FLOOR	FIRE	6R	PASS	STATIC B AIR BALANCE
6470	11/30/2018	COURT TOWER	12TH FLOOR	FIRE	18X14	PASS	STATIC B AIR BALANCE
6471	12/3/2018	COURT TOWER	12TH FLOOR	FIRE	14R	PASS	PNEUMATIC AIR BALANCE
6472	12/3/2018	COURT TOWER	12TH FLOOR	SMOKE	14R	PASS	PNEUMATIC AIR BALANCE
6473	12/3/2018	COURT TOWER	12TH FLOOR	SMOKE	7R	PASS	PNEUMATIC AIR BALANCE
6474	12/3/2018	COURT TOWER	12TH FLOOR	SMOKE	6R	PASS	NEED KEYS
6475	12/3/2018	COURT TOWER	12TH FLOOR	FIRE	6R	PASS	NEED KEYS
6476	12/4/2018	COURT TOWER	13TH FLOOR	SMOKE	12R	PASS	PNEUMATIC AIR BALANCE
6477	12/4/2018	COURT TOWER	13TH FLOOR	FIRE	12R	PASS	STATIC B AIR BALANCE
6478	12/4/2018	COURT TOWER	13TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6479	12/4/2018	COURT TOWER	13TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6480	12/4/2018	COURT TOWER	13TH FLOOR	SMOKE	6R	PASS	PNEUMATIC AIR BALANCE
6481	12/4/2018	COURT TOWER	13TH FLOOR	FIRE	6R	PASS	STATIC B AIR BALANCE
6482	XXXXXXX	COURT TOWER	XXXXX	XXXXX	XXXX	XXXX	XXXXX
6483	XXXXXXX	COURT TOWER	XXXXX	XXXXX	XXXX	XXXX	XXXXX
6484	12/4/2018	COURT TOWER	13TH FLOOR	SMOKE	11R	PASS	PNEUMATIC AIR BALANCE
6485	12/4/2018	COURT TOWER	13TH FLOOR	FIRE	11R	PASS	STATIC B AIR BALANCE
6486	12/4/2018	COURT TOWER	13TH FLOOR	FIRE	12X6	PASS	STATIC B AIR BALANCE
6487	12/11/2018	COURT TOWER	13TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE

6488	12/11/2018	COURT TOWER	13TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6489	12/11/2018	COURT TOWER	13TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6490	12/11/2018	COURT TOWER	13TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6491	12/11/2018	COURT TOWER	13TH FLOOR	FIRE	11R	PASS	STATIC B AIR BALANCE
6492	12/11/2018	COURT TOWER	13TH FLOOR	SMOKE	11R	PASS	PNEUMATIC AIR BALANCE
6493	12/11/2018	COURT TOWER	13TH FLOOR	FIRE	6R	PASS	STATIC B AIR BALANCE
6494	12/11/2018	COURT TOWER	13TH FLOOR	SMOKE	6R	PASS	PNEUMATIC AIR BALANCE
6495	12/11/2018	COURT TOWER	13TH FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6496	12/11/2018	COURT TOWER	13TH FLOOR	SMOKE	13R	PASS	PNEUMATIC AIR BALANCE
6497	12/11/2018	COURT TOWER	13TH FLOOR	FIRE	6R	PASS	STATIC B AIR BALANCE
6498	12/11/2018	COURT TOWER	13TH FLOOR	SMOKE	6R	PASS	PNEUMATIC AIR BALANCE
6499	12/11/2018	COURT TOWER	13TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6500	12/11/2018	COURT TOWER	13TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6501	12/11/2018	COURT TOWER	13TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6502	12/11/2018	COURT TOWER	13TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6503	12/11/2018	COURT TOWER	13TH FLOOR	FIRE	20X10	PASS	STATIC B AIR BALANCE
6504	12/11/2018	COURT TOWER	13TH FLOOR	FIRE	12X6	PASS	STATIC B AIR BALANCE
6505	12/11/2018	COURT TOWER	13TH FLOOR	FIRE	10X6	PASS	STATIC B AIR BALANCE
6506	12/11/2018	COURT TOWER	13TH FLOOR	FIRE	26X10	PASS	STATIC B AIR BALANCE
6507	12/5/2018	COURT TOWER	13TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6508	12/5/2018	COURT TOWER	13TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6509	12/5/2018	COURT TOWER	13TH FLOOR	FIRE	5R	PASS	STATIC B AIR BALANCE
6510	12/5/2018	COURT TOWER	13TH FLOOR	SMOKE	5R	PASS	PNEUMATIC AIR BALANCE
6511	12/5/2018	COURT TOWER	13TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6512	12/5/2018	COURT TOWER	13TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6513	12/5/2018	COURT TOWER	13TH FLOOR	FIRE	16X6	PASS	STATIC B AIR BALANCE
6514	12/5/2018	COURT TOWER	13TH FLOOR	FIRE	20X10	PASS	STATIC B AIR BALANCE
6515	12/5/2018	COURT TOWER	13TH FLOOR	FIRE	10X7	PASS	STATIC B AIR BALANCE
6516	12/5/2018	COURT TOWER	13TH FLOOR	FIRE	9X6	PASS	STATIC B AIR BALANCE
6517	12/5/2018	COURT TOWER	13TH FLOOR	FIRE	20X10	PASS	STATIC B AIR BALANCE
6518	12/6/2018	COURT TOWER	14TH FLOOR	FIRE	16X6	PASS	STATIC B AIR BALANCE
6519	12/6/2018	COURT TOWER	14TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6520	12/6/2018	COURT TOWER	14TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6521	12/6/2018	COURT TOWER	14TH FLOOR	FIRE	6R	PASS	STATIC B AIR BALANCE
6522	12/6/2018	COURT TOWER	14TH FLOOR	SMOKE	6R	PASS	PNEUMATIC AIR BALANCE
6523	12/6/2018	COURT TOWER	14TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6524	12/6/2018	COURT TOWER	14TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6525	12/6/2018	COURT TOWER	14TH FLOOR	FIRE	11R	PASS	STATIC B AIR BALANCE
6526	12/6/2018	COURT TOWER	14TH FLOOR	SMOKE	11R	PASS	PNEUMATIC AIR BALANCE

6527	12/6/2018	COURT TOWER	14TH FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6528	12/6/2018	COURT TOWER	14TH FLOOR	SMOKE	13R	PASS	PNEUMATIC AIR BALANCE
6529	12/6/2018	COURT TOWER	14TH FLOOR	FIRE	20X10	PASS	STATIC B AIR BALANCE
6530	12/6/2018	COURT TOWER	14TH FLOOR	FIRE	9X6	PASS	STATIC B AIR BALANCE
6531	12/6/2018	COURT TOWER	14TH FLOOR	FIRE	9X6	PASS	STATIC B AIR BALANCE
6532	12/6/2018	COURT TOWER	14TH FLOOR	FIRE	20X10	PASS	STATIC B AIR BALANCE
6533	12/6/2018	COURT TOWER	14TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6534	12/7/2018	COURT TOWER	14TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6535	12/7/2018	COURT TOWER	14TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6536	12/7/2018	COURT TOWER	14TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6537	12/7/2018	COURT TOWER	14TH FLOOR	FIRE	12X6	PASS	STATIC B AIR BALANCE
6538	12/7/2018	COURT TOWER	14TH FLOOR	SMOKE	10R	PASS	PNEUMATIC AIR BALANCE
6539	12/7/2018	COURT TOWER	14TH FLOOR	FIRE	10R	PASS	STATIC B AIR BALANCE
6540	12/7/2018	COURT TOWER	14TH FLOOR	SMOKE	6R	PASS	PNEUMATIC AIR BALANCE
6541	12/7/2018	COURT TOWER	14TH FLOOR	FIRE	6R	PASS	STATIC B AIR BALANCE
6542	12/7/2018	COURT TOWER	14TH FLOOR	SMOKE	9R	PASS	PNEUMATIC AIR BALANCE
6543	12/7/2018	COURT TOWER	14TH FLOOR	FIRE	9R	PASS	STATIC B AIR BALANCE
6544	12/7/2018	COURT TOWER	14TH FLOOR	SMOKE	13R	PASS	PNEUMATIC AIR BALANCE
6545	12/7/2018	COURT TOWER	14TH FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6546	12/7/2018	COURT TOWER	14TH FLOOR	SMOKE	60X12	PASS	PNEUMATIC AIR BALANCE
6547	12/10/2018	COURT TOWER	14TH FLOOR	FIRE	60X12	PASS	STATIC B AIR BALANCE
6548	12/10/2018	COURT TOWER	14TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6549	12/10/2018	COURT TOWER	14TH FLOOR	FIRE	60X12	PASS	STATIC B AIR BALANCE
6550	12/10/2018	COURT TOWER	14TH FLOOR	SMOKE	60X12	PASS	PNEUMATIC AIR BALANCE
6551	12/10/2018	COURT TOWER	14TH FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6552	12/10/2018	COURT TOWER	14TH FLOOR	SMOKE	13R	PASS	PNEUMATIC AIR BALANCE
6553	12/10/2018	COURT TOWER	14TH FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6554	12/10/2018	COURT TOWER	14TH FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6555	12/10/2018	COURT TOWER	15 TH FLOOR	FIRE	10X7	PASS	STATIC B AIR BALANCE
6556	12/10/2018	COURT TOWER	15 TH FLOOR	FIRE	20X10	PASS	STATIC B AIR BALANCE
6557	12/10/2018	COURT TOWER	15 TH FLOOR	FIRE	8X6	PASS	STATIC B AIR BALANCE
6558				XXXXX		PASS	
6559	12/10/2018	COURT TOWER	15 TH FLOOR	FIRE	20X10	PASS	STATIC B AIR BALANCE
6560	12/10/2018	COURT TOWER	15 TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6561	12/10/2018	COURT TOWER	15 TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6562	12/11/2018	COURT TOWER	15 TH FLOOR	SMOKE	11R	PASS	PNEUMATIC AIR BALANCE
6563	12/11/2018	COURT TOWER	15 TH FLOOR	FIRE	11R	PASS	STATIC B AIR BALANCE
6564	12/11/2018	COURT TOWER	15 TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6565	12/11/2018	COURT TOWER	15 TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE

6566	12/11/2018	COURT TOWER	15 TH FLOOR	SMOKE	60X12	PASS	PNEUMATIC AIR BALANCE
6567	12/11/2018	COURT TOWER	15 TH FLOOR	FIRE	60X12	PASS	STATIC B AIR BALANCE
6568	12/11/2018	COURT TOWER	15 TH FLOOR	SMOKE	60X12	PASS	PNEUMATIC AIR BALANCE
6569	12/11/2018	COURT TOWER	15 TH FLOOR	FIRE	60X12	PASS	STATIC B AIR BALANCE
6570	12/11/2018	COURT TOWER	15 TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6571	12/11/2018	COURT TOWER	15 TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6572	12/11/2018	COURT TOWER	15 TH FLOOR	SMOKE	11R	PASS	PNEUMATIC AIR BALANCE
6573	12/11/2018	COURT TOWER	15 TH FLOOR	FIRE	11R	PASS	STATIC B AIR BALANCE
6574	12/11/2018	COURT TOWER	15 TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6575	12/11/2018	COURT TOWER	15 TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6576	12/11/2018	COURT TOWER	15 TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6577	12/11/2018	COURT TOWER	15 TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6578							
6579							
6580							
6581							
6582							
6583							
6584							
6585							
6586							
6587							
6588							
6589							
6590							
6591							
6592							
6593							
6594							
6595							
6596							
6597	12/17/2018	COURT TOWER	16TH FLOOR	FIRE	11R	PASS	STATIC B AIR BALANCE
6598	12/17/2018	COURT TOWER	16TH FLOOR	SMOKE	11R	PASS	PNEUMATIC AIR BALANCE
6599	12/17/2018	COURT TOWER	16TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6600	12/17/2018	COURT TOWER	16TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6601	12/17/2018	COURT TOWER	16TH FLOOR	FIRE	6R	PASS	STATIC B AIR BALANCE
6602	12/17/2018	COURT TOWER	16TH FLOOR	SMOKE	6R	PASS	PNEUMATIC AIR BALANCE
6603	12/17/2018	COURT TOWER	16TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6604	12/17/2018	COURT TOWER	16TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE

6605	12/17/2018	COURT TOWER	16TH FLOOR	FIRE	16X6	PASS	STATIC B AIR BALANCE
6606	12/17/2018	COURT TOWER	16TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6607	12/17/2018	COURT TOWER	16TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6608	12/18/2018	COURT TOWER	16TH FLOOR	SMOKE	13R	PASS	PNEUMATIC AIR BALANCE
6609	12/18/2018	COURT TOWER	16TH FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6610	12/18/2018	COURT TOWER	16TH FLOOR	SMOKE	9R	PASS	PNEUMATIC AIR BALANCE
6611	12/18/2018	COURT TOWER	16TH FLOOR	FIRE	9R	PASS	STATIC B AIR BALANCE
6612	12/18/2018	COURT TOWER	16TH FLOOR	SMOKE	6R	PASS	PNEUMATIC AIR BALANCE
6613	12/18/2018	COURT TOWER	16TH FLOOR	FIRE	6R	PASS	STATIC B AIR BALANCE
6614	12/18/2018	COURT TOWER	16TH FLOOR	SMOKE	10R	PASS	PNEUMATIC AIR BALANCE
6615	12/18/2018	COURT TOWER	16TH FLOOR	FIRE	10R	PASS	STATIC B AIR BALANCE
6616	12/18/2018	COURT TOWER	16TH FLOOR	FIRE	12X6	PASS	STATIC B AIR BALANCE
6617	12/18/2018	COURT TOWER	16TH FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6618	12/18/2018	COURT TOWER	16TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6619	12/18/2018	COURT TOWER	16TH FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6620	12/18/2018	COURT TOWER	16TH FLOOR	SMOKE	13R	PASS	PNEUMATIC AIR BALANCE
6621	12/18/2018	COURT TOWER	16TH FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6622	12/19/2018	COURT TOWER	16TH FLOOR	SMOKE	13R	PASS	PNEUMATIC AIR BALANCE
6623	12/19/2018	COURT TOWER	16TH FLOOR	FIRE	10X7	PASS	STATIC B AIR BALANCE
6624	12/19/2018	COURT TOWER	16TH FLOOR	FIRE	20X10	PASS	STATIC B AIR BALANCE
6625	12/19/2018	COURT TOWER	16TH FLOOR	FIRE	10X8	PASS	STATIC B AIR BALANCE
6626	12/19/2018	COURT TOWER	16TH FLOOR	FIRE	20X10	PASS	STATIC B AIR BALANCE
6627	12/19/2018	COURT TOWER	16TH FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6628	12/19/2018	COURT TOWER	16TH FLOOR	SMOKE	13R	PASS	PNEUMATIC AIR BALANCE
6629	12/19/2018	COURT TOWER	16TH FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6630	12/19/2018	COURT TOWER	16TH FLOOR	SMOKE	60X12	PASS	PNEUMATIC AIR BALANCE
6631	12/19/2018	COURT TOWER	16TH FLOOR	FIRE	60X12	PASS	STATIC B AIR BALANCE
6632	12/19/2018	COURT TOWER	16TH FLOOR	SMOKE	60X12	PASS	PNEUMATIC AIR BALANCE
6633	12/19/2018	COURT TOWER	16TH FLOOR	FIRE	60X12	PASS	STATIC B AIR BALANCE
6634	12/19/2018	COURT TOWER	16TH FLOOR	SMOKE	13R	PASS	PNEUMATIC AIR BALANCE
6635	12/19/2018	COURT TOWER	16TH FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6636	12/20/2019	COURT TOWER	17th FLOOR	FIRE	20X10	PASS	STATIC B AIR BALANCE
6637	12/20/2019	COURT TOWER	17th FLOOR	FIRE	8X8	PASS	STATIC B AIR BALANCE
6638	12/20/2019	COURT TOWER	17th FLOOR	FIRE	8X8	PASS	STATIC B AIR BALANCE
6639	12/20/2019	COURT TOWER	17th FLOOR	FIRE	20X10	PASS	STATIC B AIR BALANCE
6640	12/20/2019	COURT TOWER	17th FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6641	12/20/2019	COURT TOWER	17th FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6642	12/20/2019	COURT TOWER	17th FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE
6643	12/20/2019	COURT TOWER	17th FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE

6644	12/20/2019	COURT TOWER	17th FLOOR	SMOKE	13R	PASS	PNEUMATIC AIR BALANCE
6645	12/20/2019	COURT TOWER	17th FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6646	12/20/2019	COURT TOWER	17th FLOOR	SMOK E	13R	PASS	PNEUMATIC AIR BALANCE
6647	12/20/2019	COURT TOWER	17th FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6648	12/20/2019	COURT TOWER	17th FLOOR	SMOKE	13R	PASS	PNEUMATIC AIR BALANCE
6649	12/20/2019	COURT TOWER	17th FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6650	12/20/2019	COURT TOWER	17th FLOOR	SMOKE	13R	PASS	PNEUMATIC AIR BALANCE
6651	12/26/2019	COURT TOWER	17th FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6652	12/26/2019	COURT TOWER	17th FLOOR	SMOKE	11R	PASS	PNEUMATIC AIR BALANCE
6653	12/26/2019	COURT TOWER	17th FLOOR	FIRE	11R	PASS	STATIC B AIR BALANCE
6654	12/26/2019	COURT TOWER	17th FLOOR	SMOKE	6R	PASS	PNEUMATIC AIR BALANCE
6655	12/26/2019	COURT TOWER	17th FLOOR	FIRE	6R	PASS	STATIC B AIR BALANCE
6656	12/26/2019	COURT TOWER	17th FLOOR	SMOKE	7R	PASS	PNEUMATIC AIR BALANCE
6657	12/26/2019	COURT TOWER	17th FLOOR	FIRE	7R	PASS	STATIC B AIR BALANCE
6658	12/26/2019	COURT TOWER	17th FLOOR	SMOKE	10R	PASS	PNEUMATIC AIR BALANCE
6659	12/26/2019	COURT TOWER	17th FLOOR	FIRE	10R	PASS	STATIC B AIR BALANCE
6660	12/26/2019	COURT TOWER	17th FLOOR	FIRE	18X8	PASS	STATIC B AIR BALANCE
6661	12/26/2019	COURT TOWER	17th FLOOR	FIRE	13R	PASS	STATIC B AIR BALANCE
6662	12/26/2019	COURT TOWER	17th FLOOR	SMOKE	13R	PASS	PNEUMATIC AIR BALANCE
6663	12/26/2019	COURT TOWER	17th FLOOR	FIRE	6R	PASS	STATIC B AIR BALANCE
6664	12/26/2019	COURT TOWER	17th FLOOR	SMOKE	6R	PASS	PNEUMATIC AIR BALANCE
6665	12/26/2019	COURT TOWER	17th FLOOR	FIRE	6R	PASS	STATIC B AIR BALANCE
6666	12/26/2019	COURT TOWER	17th FLOOR	SMOKE	6R	PASS	PNEUMATIC AIR BALANCE
6667	12/26/2019	COURT TOWER	17th FLOOR	FIRE	11R	PASS	STATIC B AIR BALANCE
6668	12/27/2018	COURT TOWER	17th FLOOR	SMOKE	11R	PASS	PNEUMATIC AIR BALANCE
6669	12/27/2018	COURT TOWER	17th FLOOR	FIRE	8R	PASS	STATIC B AIR BALANCE
6670	12/27/2018	COURT TOWER	17th FLOOR	SMOKE	8R	PASS	PNEUMATIC AIR BALANCE