



NOTE:

House connections shall be connected into the top half of the sewer pipe.
 six inch, class 200, cast iron pipe is required for all bored sewer service connections
 including slip on rubber joints with an ANSI thickness classification No.25, also
 6 inch, ductile iron cement lined pipe may be used including slip on rubber joints
 with an ANSI thickness classification No. 53.

LATERAL
 CONNECTIONS

REVISIONS:	SCALE NO SCALE	DATE : DEC. 1998
------------	-------------------	------------------

UNIFORM STANDARDS: CLEVELAND --- CUYAHOGA COUNTY --- NORTHEAST OHIO REGIONAL SEWER DISTRICT