



NOTE:

Grout pipe opening with cement mortar mix 1:2 if pipe is either CLAY or CONCRETE, use premium joint if pipe is flexible.

Locations where the 3' minimum is not possible lesser depths are acceptable.

Square catch basins will be accepted as an alternative.

Catch basin will be constructed per O.D.O.T. item No. 604 and 706.13, PRECAST will have a minimum of 4" reinforced wall.

SQUARE CATCH BASIN CASTINGS – EAST JORDAN No. 5110 sinusoidal grate type M-4 or NEENAH R-4859-C.

All grates shall be bicycle safe.

YARD TYPE
CATCH BASIN

REVISIONS:

SCALE
NO SCALE

DATE : DEC. 1998

UNIFORM STANDARDS: CLEVELAND ---- CUYAHOGA COUNTY ---- NORTHEAST OHIO REGIONAL SEWER DISTRICT