



6" LATERAL BORING

NOTE:

DRILLING FLUID TO REMAIN OR ANNULAR SPACE TO BE GROUTED.

TYPES OF ACCEPTABLE PIPE:

1. FUSIBLE PVC CONFORMING TO AWWA C900 OR C905; MINIMUM SDR 21 PRESSURE CLASS 200 PSI.
2. RESTRAINED JOINT PVC WITH PIPE AND COUPLING CONFORMING TO SDR 21 PRESSURE CLASS 200 PSI.
3. FUSIBLE HDPE CONFORMING TO ASTM F-714 AND AWWA C906; MINIMUM DR17.
4. ALL PIPE SHALL BE IRON PIPE SIZE (IPS).

LATERAL BORING
DETAIL

REVISIONS:

SCALE
NO SCALE

DATE SEPTEMBER 18, 2018

UNIFORM STANDARDS: CLEVELAND --- CUYAHOGA COUNTY --- NORTHEAST OHIO REGIONAL SEWER DISTRICT