



NOTES
 The cylindrical section of the manholes shall be extended vertically from the shelves for a distance equal to the internal diameter of the largest pipe entering the manhole, with a minimum vertical height of 4' - 0".

**BRICK MANHOLE
 FOR STORM SEWER**

REVISIONS: SCALE
NO SCALE DATE: DEC. 1998

UNIFORM STANDARDS: CLEVELAND --- CUYAHOGA COUNTY --- NORTHEAST OHIO REGIONAL SEWER DISTRICT